

**CONFIDENT GREENFIELD****CUBE TEST RESULT****GROUND ,1<sup>st</sup> FLOOR COLUMN AND FLOOR SLAB**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )		CHARACTERISTIC COMPRESSIVE STRENGTH(N/mm <sup>2</sup> )	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	22.03.23	ELEVENTH FLOOR SLAB	M25	16.66	25	19.55	26.22
2	25.03.23	ELEVENTH FLOOR SLAB	M25	16.66	25	18.22	25.7
3	30.03.23	STP	M30	20.00	30	23.25	30.96
4	02.04.23	ELEVENTH FLOOR COLUMN	M35	23.33	35	26.37	35.11
5	03.04.23	ELEVENTH FLOOR COLUMN	M35	23.33	35	25.77	36.14
6	04.04.23	ELEVENTH FLOOR COLUMN	M35	23.33	35	25.03	35.4
7	08.04.23	ELEVENTH FLOOR COLUMN	M35	23.33	35	25.33	35.25
8	11.04.23	ELEVENTH FLOOR SLAB	M25	16.66	25	19.33	35.85