CONFIDENT GREEN VALLEY

CUBE TEST RESULT-MARCH

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH(N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH(N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	13/02/16	P60	M25	16.67	25	17.77	31.04