

CONFIDENT HORIZON							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	06/07/25	Sump Tank Roof Slab	M25	16.66	25	17.33	25.7
2	16/06/25	Retaining wall west side	M30	20	30	20.74	31.3
3	23/06/25	OHT tank wall	M30	20	30	20.74	31.33
4	30/06/25	OHT cover slab	M25	16.66	25	17.33	25.62