

| CONFIDENT HORIZON |                 |                      |                   |                                          |         |                                             |         |
|-------------------|-----------------|----------------------|-------------------|------------------------------------------|---------|---------------------------------------------|---------|
| CUBE TEST RESULT  |                 |                      |                   |                                          |         |                                             |         |
| SL NO             | DATE OF CASTING | DESCRIPTION          | GRADE OF CONCRETE | PERMISSIBLE COMPRESSIVE STRENGTH (N/mm2) |         | CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2) |         |
|                   |                 |                      |                   | 7 DAYS                                   | 28 DAYS | 7 DAYS                                      | 28 DAYS |
| 1                 | 10/05/25        | Sump tank wall       | M30               | 20                                       | 30      | 21.03                                       | 31.33   |
| 2                 | 11/05/25        | Sump tank wall       | M30               | 20                                       | 30      | 20.74                                       | 31.33   |
| 3                 | 17/05/25        | Fire stair head room | M25               | 16.66                                    | 25      | 17.33                                       | 29.33   |
| 4                 | 19/05/25        | Lift head room       | M25               | 16.66                                    | 25      | 17.33                                       | 25.62   |
| 5                 | 29/05/25        | Main stair head room | M25               | 16.66                                    | 25      | 20                                          | 25.85   |
| 6                 | 06/03/25        | OHT Baseslab         | M25               | 16.66                                    | 25      | 17.67                                       | 25.62   |

