

**CONFIDENT GREENWICH, CALICUT****CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH(N/mm <sup>2</sup> )		CHARACTERISTIC COMPRESSIVE STRENGTH(N/mm <sup>2</sup> )	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	09/11/22	GF Slab	M30	20	30	20.70	30.22
2	16/11/22	1 <sup>st</sup> Floor slab	M25	16.66	25	23.40	25.1
3	17/11/22	1 <sup>st</sup> Floor slab	M25	16.66	25	22.74	25.25
4	18/11/22	Sump wall	M30	20	30	21.26	30.37
5	22/11/22	Column GF& UB	M40	26.66	40	28.40	41.4
6	28/11/22	Sump wall	M30	20	30	22.52	30.96
7	02/12/22	FF Shear wall	M40	26.66	40	27.00	40.59
8	03/12/22	Sump tank cover slab	M30	20	30	20.00	30.37
9	05/12/22	UB slab	M30	20	30	20.88	31.8
10	09/12/22	FF column	M40	26.66	40	27.10	41.18
11	10/12/22	UB Column	M40	26.66	40	27.00	40.81