CONFIDENT SUNFLOWER, VENNALA

CUBE TEST RESULT

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	05/09/26	Swimming pool-Deck slab	M 25	16.66	25.00	20.37	27.03