

CONFIDENT SILVEROAK, KOTTAYAM**CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH (N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm ²)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	05/04/25	Boundary retaining wall (1 st lift)	M30	20	30	21.77	30.37
2	07/04/25	Upper Basement retaining wall baseslab	M30	20	30	21.40	30.22
3	09/04/25	Boundary retaining wall (2 nd lift)	M30	20	30	21.33	30.14
4	11/04/25	Upper Basement retaining wall concrete	M30	20	30	21.55	30.37
5	12/04/25	Upper Basement retaining wall concrete	M30	20	30	21.25	30.29
6	23/04/25	Retaining wall Baseslab	M30	20	30	21.48	30.37
7	24/04/25	Boundary retaining wall baseslab concrete	M30	20	30	21.48	30.37
8	26/04/25	First floor slab unit 6	M25	16.66	25	19.40	28.52

9	27/04/25	Boundary retaining wall	M30	20	30	21.70	30.37
10	28/04/25	Upper basement parking slab	M25	16.66	25	19.44	26.00
11	30/04/25	First floor slab unit 6	M25	16.66	25	18.36	25.70
12	02/04/25	Retaining wall concrete	M30	20	30	22.59	30.51
13	03/04/25	Retaining wall concrete	M30	20	30	21.48	30.00