

CONFIDENT FANTASY CALICUT							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIP TION	GRADE OF CONCRET E	PERMISSIBLE COMPRESSIVE STRENGTH(N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH(N/mm ²)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	09-05-26	P150	M30	20	30	20.67	30.89
2	09-05-26	P143	M30	20	30	21.11	30.3
3	11-05-26	P124	M30	20	30	23.11	30.37
4	11-05-26	P157	M30	20	30	22.22	30.81
5	12-05-26	P89	M30	20	30	22.67	30.37
6	13-05-26	P149	M30	20	30	22.74	31.56
7	13-05-26	P154	M30	20	30	24.22	30.29
8	14-05-26	P90	M30	20	30	21.93	30.37
9	14-05-26	P137	M30	20	30	22.00	30.07
10	15-05-26	P156	M30	20	30	22.59	30.3
11	15-05-26	P91	M30	20	30	22.00	31.04
12	16-05-26	P138	M30	20	30	23.93	31.41
13	16-05-26	P155	M30	20	30	23.41	30.89

14	18-05-26	P92	M30	20	30	22.44	30.59
15	19-05-26	P140	M30	20	30	22.37	30.67
16	20-05-26	P110	M30	20	30	22.96	31.19
17	20-05-26	P133	M30	20	30	25.19	30.07
18	21-05-26	P117	M30	20	30	22.96	30.44
19	21-05-26	P111	M30	20	30	23.33	30.89
20	22-05-26	P131	M30	20	30	20.15	32.23
21	23-05-26	P115	M30	20	30	20.37	30.96
22	23-05-26	P112	M30	20	30	20.00	30.15
23	23-05-26	P130	M30	20	30	20.37	30.44
24	25-05-26	P113	M30	20	30	20.63	30.22
25	25-05-26	P116	M30	20	30	20.59	30.15
26	26-05-26	P139	M30	20	30	20.52	30.22
27	26-05-26	P114	M30	20	30	20.52	31.33
28	27-05-26	P119	M30	20	30	20.44	31.48
29	27-05-26	P104	M30	20	30	20.00	31.41
30	28-05-26	P129	M30	20	30	20.15	30.81
31	28-05-26	P106	M30	20	30	21.19	31.85

32	29-05-26	P118	M30	20	30	23.33	31.33
33	29-05-26	P105	M30	20	30	21.86	30.59
34	30-05-26	P127	M30	20	30	20.37	30.89
35	30-05-26	P101	M30	20	30	24.07	31.63
36	01-06-26	P109	M30	20	30	20.37	30.00
37	02-06-26	P128	M30	20	30	20.89	31.64
38	02-06-26	P100	M30	20	30	22.07	31.33
39	03-06-26	P107	M30	20	30	21.38	30.00
40	04-06-26	P141	M30	20	30	22.22	30.67
41	04-06-26	P108	M30	20	30	20.81	30
42	08-06-26	P102	M30	20	30	21.63	30.59
43	09-06-26	P70	M30	20	30	22.29	30.44