

**CONFIDENT SUNFLOWER, VENNALA****CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm <sup>2</sup> )		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	10/03/25	11 <sup>th</sup> floor – slab unit 3&4	M 25	16.66	25.00	20.37	26.67
2	18/10/25	12 <sup>th</sup> floor unit 1,2 &5	M 25	16.66	25.00	21.07	35.68
3	31/10/25	12 <sup>th</sup> floor unit 3&4	M 25	16.66	25.00	21.10	30.90