

CONFIDENT WHITEHOUSE, KALOOR							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	15/10/25	Ladies swimming pool wall	M30	20	30	23.48	34.00
2	16/10/25	Kids swimming pool base slab	M30	20	30	24.52	35.33
3	24/10/25	OHT & Flush tank RCC Wall	M30	20	30	24.30	33.85
4	30/10/25	Ladies Swimming pool Deck slab	M30	20	30	23.48	34.29

