

CONFIDENT HERITAGE, FORT KOCHI**CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm ²)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	08/08/25	Pile cap	M 30	20	30	20.10	35.62
2	19/08/25	Pile cap	M 30	20	30	29.76	35.85
3	27/08/25	Pile cap	M 30	20	30	28.90	35.70
4	02/09/25	Pile cap	M 30	20	30	22.22	31.70
5	29/09/25	Pile cap	M 30	20	30	22.66	31.70
6	14/10/25	Base slab - 1 st portion	M 30	20	30	25.77	32.44
7	24/10/25	Basement Column	M 35	23.33	35	25.18	36.00
8	24/10/25	Retaining wal	M 30	20	30	22.22	34.22
9	30/10/25	Base slab / STP - 2 nd portion	M 30	20	30	24.59	33.33