

CONFIDENT EBONY, THRISSUR**CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm ²)	
				7 Days	28 Days	7 Days	28 Days
1	20/11/25	RETAINING WALL – FRONT COMPOUND WALL	M25	16.66	25	17.16	25.55
2	28/11/25	OHT – WALL	M30	20	30	21.96	30.22
3	02/12/25	SWIMMING POOL – BASE SLAB	M30	20	30	20.16	30.37