

**CONFIDENT BLISS , THRISSUR****CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm <sup>2</sup> )		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )	
				7 Days	28 Days	7 Days	28 Days
1	03/11/25	COLUMN : FF	M30	20	30	22.22	31.26
2	06/11/25	FF SLAB (SOUTH SIDE)	M25	16.66	25	18.74	25.44
3	10/11/25	FF COLUMN :68,69,56,60,81,82,83	M30	20	30	22.14	31.4
4	12/11/25	STAIR : FF	M25	16.66	25	18.96	28.73
5	18/11/25	THIRD SLAB :7,8 SERIES	M25	16.66	25	21.77	27
6	22/11/25	COLUMN : C40,41,42,26,37,25	M30	20	30	21.33	31.56
7	25/11/25	TYPICAL STAIR-1ST FLOOR	M25	16.66	25	19.94	26.9
8	27/11/25	3RD SLAB 1,2 SERIES	M25	16.66	25	21.66	25.03
9	28/11/25	PC3,PC7,PC5,C90,PC4A,PC3A	M30	20	30	21.30	30.96
10	29/11/25	PC7A,PC3B,PC6A,C78,C80,C71	M30	20	30	20.51	31.4
11	05/12/25	COLUMN 2ND FLOOR	M30	20	30	22.44	30.96
12	09/12/25	3RD SLAB 5,6 SERIES	M25	16.66	25	19.69	25.33
13	13/12/25	3RD SLAB 3,4 SERIES	M25	16.66	25	19.97	25.48
14	19/12/25	4TH SLAB 7,8 SERIES	M25	16.66	25	18.74	25.3

15	20/12/25	COLUMN 2ND FLOOR-3,4 SERIES	M30	20	30	21.25	30.15
16	22/12/25	4TH SLAB 1,2 SERIES	M25	16.66	25	18.00	25.55
17	26/12/25	COLUMN THIRD LOOR -71,65,64,77,78	M30	20	30	21.04	30.22
18	29/12/25	COLUMN THIRD FLOOR -38,39,21,22,23,24,31	M30	20	30	21.85	30.22
19	30/12/25	MAIN STAIR -SECOD FLOOR	M25	16.66	25	20.20	26.3
20	02/01/26	FOURTH SLAB RCC -5 &6 SERIES	M25	16.66	25	20.20	25.33
21	05/01/26	FOURTH SLAB RCC – 3&4 SERIES	M25	16.66	25	18.22	26.14