

CONFIDENT EBONY, THRISSUR**CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm ²)	
				7 Days	28 Days	7 Days	28 Days
1	09/12/25	OHT – COVER SLAB	M30	20	30	20.62	30.29
2	01/01/26	SWIMMING POOL – DECK SLAB	M30	20	30	20.59	30.22