

CONFIDENT BLISS , THRISSUR**CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm ²)	
				7 Days	28 Days	7 Days	28 Days
1	07/01/26	THIRD FLOOR COLUMN -5&6 SERIES(67,68,69,70,73,81,82,83,84)	M30	20	30	21.93	30.66
2	13/01/26	THIRD FLOOR COLUMN - 3&4 SERIES	M30	20	30	22.20	30.22
3	15/01/26	FIFTH SLAB- 7&8 SERIES	M25	16.66	25	19.41	25.48
4	17/01/26	FIFTH SLAB -1&2 SERIES	M25	16.66	25	20.37	25.55
5	19/01/26	FOURTH FLOOR COLUMN -7&8 SERIES	M30	20	30	22.96	30.96
6	23/01/26	BASEMENT FLOOR COLUMN (116,112,122,121)	M30	20	30	20.52	32.74
7	28/01/26	FIFTH SLAB -5&6 ERIES	M25	16.66	25	19.41	25.85
8	30/01/26	3RD FOOR STAIRS	M25	16.66	25	20.20	25.55
9	02/02/26	FOURTH FLOOR COLUMN -5&6 SERIES	M30	20	30	22.00	30.81
10	03/02/26	FIFTH SLAB -3&4 SERIES	M25	16.66	25	21.80	26.66
11	06/06/26	FOURTH FLOOR COLUMN	M30	20	30	22.66	30.66
12	10/02/26	SIXTH SLAB-7&8 SERIES	M25	16.66	25	20.19	25.55
13	13/02/26	SIXTH SLAB-1&2 SERIES	M25	16.66	25	22.00	25.55
14	14/02/26	TOWER 1 STAIR BASEMENT FLOOR	M25	16.66	25	19.40	26.9

15	21/02/26	FIFTH FLOOR COUMN -7& 8 SERIES	M30	20	30	22.96	31.56
16	24/02/26	6TH SLAB 5&8 SERIES	M25	16.66	25	18.22	26.9
17	26/02/26	6TH SLAB 3& 4 SERIES	M25	16.66	25	18.66	25.55
18	28/02/26	FIRE TANK SIDE WALL	M30	20	30	22.51	30.59