

CONFIDENT FAIRFIELD, TRIVANDRUM							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH(N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	04/06/2026	basement south side retaining wall	M30	20	30	22.220	30.22
2	06/06/2026	10 th floor 5 series slab concrete	M25	16.66	25	17.700	26.37
3	11/06/2026	10 th floor 4 series slab concrete	M25	16.66	25	18.140	26.29
4	17/06/2026	10 th floor 2 series slab concrete	M25	16.66	25	17.620	26.81
5	20/06/2026	10 th floor 1 series slab concrete	M25	16.66	25	17.480	25.18
6	23/06/2026	10 th floor 8 series slab concrete	M25	16.66	25	17.700	26.00
7	25/06/2026	GF slab concrete	M25	16.66	25	17.700	25.41

