

CONFIDENT FANTASY CALICUT							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIP TION	GRADE OF CONCRET E	PERMISSIBLE COMPRESSIVE STRENGTH(N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH(N/mm ²)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	10-06-26	P103	M30	20.00	30.00	21.33	30.44
2	11-06-26	P71	M30	20.00	30.00	22.00	30.37
3	11-06-26	P99	M30	20.00	30.00	21.04	30.96
4	12-06-26	P72	M30	20.00	30.00	21.41	31.56
5	13-06-26	P98	M30	20.00	30.00	20.59	32.37
6	13-06-26	P69	M30	20.00	30.00	21.48	31.85
7	15-06-26	P74	M30	20.00	30.00	21.85	30.15
8	16-06-26	P67	M30	20.00	30.00	21.48	30.81
9	16-06-26	P75	M30	20.00	30.00	22.96	31.18
10	20-06-26	P68	M30	20.00	30.00	21.26	30.81
11	20-06-26	P73	M30	20.00	30.00	20.59	30.81
12	22-06-26	P49	M30	20.00	30.00	20.74	30.30

13	23-06-26	P76	M30	20.00	30.00	20.74	30.00
14	23-06-26	P66	M30	20.00	30.00	20.00	30.96
15	24-06-26	P62	M30	20.00	30.00	20.76	30.15
16	25-06-26	P65	M30	20.00	30.00	20.22	30.37
17	26-06-26	P142	M30	20.00	30.00	20.96	30.66
18	26-06-26	P64	M30	20.00	30.00	20.22	30.52
19	27-06-26	P63	M30	20.00	30.00	22.30	31.70
20	29-06-26	P120	M30	20.00	30.00	20.67	31.70
21	30-06-26	P51	M30	20.00	30.00	21.18	30.22
22	30-06-26	P61	M30	20.00	30.00	22.15	30.89
23	01-07-26	P122	M30	20.00	30.00	21.93	30.15
24	02-07-26	P50	M30	20.00	30.00	22.37	30.37
25	02-07-26	P123	M30	20.00	30.00	20.96	30.44
26	03-07-26	P121	M30	20.00	30.00	20.85	30.52
27	04-07-26	P60	M30	20.00	30.00	21.19	30.59
28	06-07-26	P53	M30	20.00	30.00	22.15	31.48
29	06-07-26	P93	M30	20.00	30.00	21.11	30.52