

CONFIDENT HERITAGE, FORT KOCHI							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	4/6/26	FF slab and beam - 1 st portion	M25	16.66	25	17.05	26.12
2	29/6/26	Grade beam and grade slab	M30	20	30	24.55	32.22
3	7/7/26	North side RW	M30	20	30	21.33	30.86