

CONFIDENT SILVEROAK, KOTTAYAM							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	10/06/26	10 th floor column concrete	M35	23.33	35	25.66	35.92
2	12/06/26	13 th slab concrete	M25	16.66	25	21.40	25.77
3	15/06/26	13 th slab concrete	M25	16.66	25	21.11	25.85
4	17/06/26	11 th floor column concrete	M35	23.33	35	25.55	35.77
5	18/06/26	11 th floor column concrete	M35	23.33	35	25.77	35.77
6	20/06/26	13 th slab concrete (4 and 5 series)	M25	16.66	25	21.03	25.85
7	22/06/26	13 th slab concrete (6 series)	M25	16.66	25	20.96	25.11
8	24/06/26	11 th floor column concrete	M35	23.33	35	25.18	35.85

9	27/06/26	11 th floor column concrete	M35	23.33	35	25.11	35.62
10	29/06/26	11 th floor column concrete	M35	23.33	35	25.11	35.77
11	30/06/26	11 th floor column concrete	M35	23.33	35	25.11	35.85
12	04/07/26	14 th slab concrete 7 and 8 th series	M25	16.66	25	21.33	25.25
13	06/07/26	upper Basement slab concrete	M25	16.66	25	21.11	25.25
14	08/07/26	11 th floor column concrete	M35	23.33	35	24.46	35.94
15	09/07/26	14 th slab concrete 9 th series	M25	16.66	25	21.18	25.85
16	15/07/26	14 th slab concrete 2 and 3 series	M25	16.66	25	21.03	25.77