

CONFIDENT BLISS , THRISSUR**CUBE TEST RESULT**

SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 Days	28 Days	7 Days	28 Days
1	15/06/26	7TH FLOOR COLUMN 5&6 SERIES	M30	20	30	20.96	30.96
2	16/06/26	GF SLAB (TOWER 1)	M25	16.66	25	19.41	26
3	20/06/26	9TH SLAB 7&8 SERIES	M25	16.66	25	18.22	26.9
4	22/06/26	GF COLUMN 1&2 SERIES (TOWER 1)	M30	20	30	22.00	30.37
5	23/06/26	9TH SLAB 1&2 SERIES	M25	16.66	25	18.15	25.56
6	27/06/26	GF COLUMN 7&8 SERIES (TOWER 1)	M30	20	30	22.44	30.66
7	29/06/26	8TH FLOOR COLUMN 7&8 SERIES	M30	20	30	22.07	30.59
8	30/06/26	9TH SLAB 5&6 SERIES	M25	16.66	25	18.81	25.85
9	07/07/26	9TH SLAB 3&4 SERIES	M25	16.66	25	18.74	26.9
10	14/07/26	GF COLUMN 5&6 SERIES (TOWER 1)	M30	20	30	22.96	30.66
11	15/07/26	10TH SLAB 7&8 SERIES	M25	16.66	25	22.00	25.56
12	18/07/26	GF COLUMN 3&4 SERIES (TOWER 1)	M30	20	30	22.96	30.37
13	20/07/26	8TH FLOOR COLUMN 3&4 SERIES	M30	20	30	22.56	30.96
14	21/07/26	10TH SLAB 1&2 SERIES	M25	16.66	25	19.41	26.9

15	22/07/26	2ND SLAB 1&2 SERIES (TOWER 1)	M25	16.66	25	18.15	25.56
16	28/07/26	10TH SLAB 5&6 SERIES	M25	16.66	25	18.29	25.56
17	31/07/26	10TH SLAB 3&4 SERIES	M25	16.66	25	19.41	25.85
18	04/08/26	9TH FLOOR COLUMN 7&8 SERIES	M30	20	30	20.75	30.37
19	04/08/26	1ST FLOOR COLUMN 1&2 SERIES (TOWER 1)	M30	20	30	22.00	30.66