

CONFIDENT FANTASY CALICUT							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIP TION	GRADE OF CONCRET E	PERMISSIBLE COMPRESSIVE STRENGTH(N/mm ²)		CHARACTERISTIC COMPRESSIVE STRENGTH(N/mm ²)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	07-07-26	P52	M30	20.00	30.00	21.04	30.15
2	07-07-26	P88	M30	20.00	30.00	20.96	30.59
3	09-07-26	P94	M30	20.00	30.00	20.44	30.15
4	09-07-26	P87	M30	20.00	30.00	21.04	30.29
5	10-07-26	P95	M30	20.00	30.00	20.74	30.30
6	10-07-26	P55	M30	20.00	30.00	20.44	30.22
7	11-07-26	P85	M30	20.00	30.00	20.74	30.89
8	13-07-26	P97	M30	20.00	30.00	20.07	30.96
9	14-07-26	P54	M30	20.00	30.00	20.00	31.63
10	14-07-26	P82	M30	20.00	30.00	21.76	30.81
11	15-07-26	P96	M30	20.00	30.00	21.04	31.33
12	15-07-26	P31	M30	20.00	30.00	20.81	30.15
13	16-07-26	P83	M30	20.00	30.00	20.00	34.59

14	17-07-26	P78	M30	20.00	30.00	22.15	30.00
15	17-07-26	P29	M30	20.00	30.00	23.04	30.22
16	21-07-26	P77	M30	20.00	30.00	21.41	30.15
17	22-07-26	P48	M30	20.00	30.00	20.15	30.07
18	22-07-26	P84	M30	20.00	30.00	20.29	32.07
19	23-07-26	P20	M30	20.00	30.00	21.41	31.04
20	23-07-26	P47	M30	20.00	30.00	23.85	31.41
21	24-07-26	P79	M30	20.00	30.00	20.59	30.44
22	25-07-26	P45	M30	20.00	30.00	21.41	30.00
23	25-07-26	P21	M30	20.00	30.00	20.81	30.22
24	27-07-26	P80	M30	20.00	30.00	21.70	36.59
25	27-07-26	P46	M30	20.00	30.00	20.59	30.52
26	28-07-26	P19	M30	20.00	30.00	20.95	30.22
27	28-07-26	P40	M30	20.00	30.00	21.63	30.00
28	29-07-26	P81	M30	20.00	30.00	22.52	30.90
29	29-07-26	P18	M30	20.00	30.00	22.44	35.26
30	30-07-26	P41	M30	20.00	30.00	23.03	34.15
31	30-07-26	P11	M30	20.00	30.00	21.85	33.11

32	31-07-26	P59	M30	20.00	30.00	22.74	30.07
33	04-08-26	P33	M30	20.00	30.00	20.00	30.52
34	05-08-26	P17	M30	20.00	30.00	21.81	30.07
35	05-08-26	P39	M30	20.00	30.00	20.75	32.15
36	06-08-26	P10	M30	20.00	30.00	20.44	32.44
37	06-08-26	P38	M30	20.00	30.00	22.07	31.93
38	07-08-26	P36	M30	20.00	30.00	21.86	34.37
39	10-08-26	P58	M30	20.00	30.00	20.37	31.11
40	11-08-26	P37	M30	20.00	30.00	20.59	32.52