

CONFIDENT SILVEROAK, KOTTAYAM							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE COMPRESSIVE STRENGTH (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	18/07/26	12 th floor column concrete	M35	23.33	35	25.18	35.85
2	21/07/26	14 th slab concrete 4 and 5 series	M35	23.33	35	25.25	35.11
3	24/07/26	12 th floor column concrete	M35	23.33	35	25.48	35.77
4	25/07/26	12 th floor column concrete	M35	23.33	35	24.96	35.25
5	27/07/26	12 th floor Shear wall concrete	M35	23.33	35	25.18	35.33
6	28/07/26	12 th floor column concrete	M35	23.33	35	25.25	35.11
7	29/07/26	12 th floor Shear wall concrete	M35	23.33	35	25.11	35.77
8	30/07/26	12 th floor column concrete	M35	23.33	35	25.18	35.40
9	31/07/26	12 th floor column concrete	M35	23.33	25	24.88	35.85

