CONFIDENT HERITAGE, FORT KOCHI							
CUBE TEST RESULT							
SL NO	DATE OF CASTING	DESCRIPTION	GRADE OF CONCRETE	PERMISSIBLE LIMIT (N/mm2)		CHARACTERISTIC COMPRESSIVE STRENGTH (N/mm2)	
				7 DAYS	28 DAYS	7 DAYS	28 DAYS
1	5/8/26	Grade beam and grade slab	M30	20	30	22.52	35.33
2	20/8/26	First floor roof slab - 1st portion	M25	16.66	25	17.12	30.08